

**Guide Specification****PART 1 GENERAL****1.1 SUMMARY**

- A. Provide labor, materials, equipment and supervision necessary to install a seamless, fully adhered fluid-applied roofing over new or existing built-up and modified bitumen roofing as outlined in this specification.
- B. The Manufacturer's Application Instructions for each product used are considered part of this specification and should be followed at all times.
- C. Related Sections:
 - 1. Cast-in-Place Concrete: Section 03 30 __.
 - 2. Metal Decking: Section 05 30 __.
 - 3. Wood Decking: Section 06 15 __.
 - 4. Thermal Protection: Section 07 20 __.
 - 5. Flashing & Sheet Metal: Section 07 60 __.
 - 6. Roof Accessories: Section 07 72 __.
 - 7. Joint Sealants: Section 07 92 __.

1.2 SYSTEM DESCRIPTION

- A. ELASTA-GARD™ BUR/MB shall be a complete system of compatible materials to create a seamless waterproof membrane.
- B. ELASTA-GARD™ BUR/MB shall be designated for application on the specific type of deck indicated on the drawings.

1.3 SUBMITTALS

- A. Product Data: Submit NEOGARD® product literature and installation instructions.
- B. Project Reference List: Submit list of projects as required by this specification.
- C. Samples: Submit samples of specified fluid-applied roof system. Samples shall be construed as examples of finished color and texture only.
- D. Applicator Approval: Submit letter from manufacturer stating applicator is approved to install the ELASTA-GARD™ BUR/MB system.

- E. Warranty: Submit copy of manufacturers standard warranty.

1.4 QUALITY ASSURANCE

- A. Supplier Qualifications: ELASTA-GARD™ BUR/MB, as supplied by NEOGARD®, is approved for use on this project.
- B. Applicator Qualifications: Applicators shall be approved to install specified system.
- C. Requirements of Regulatory Agencies:
 - 1. The fluid-applied roofing system shall be rated Class "A" by Underwriters Laboratories (ASTM E108/UL 790). Containers to bear Underwriters Laboratories labels.
 - 2. Materials used in the fluid-applied roofing system shall meet Federal, State and local VOC regulations.
- D. Field Quality Control: Upon completion of the ELASTA-GARD™ BUR/MB installation, an inspection by NEOGARD® or its designated third party inspection company may be required. Consult NEOGARD® for details.

1.5 DELIVERY, STORAGE AND HANDLING

- A. Delivery: Materials shall be delivered in original sealed containers, clearly marked with supplier's name, brand name and type of material.
- B. Storage and Handling: Recommended material storage temperature is 75°F (23.8°C). Handle products to avoid damage to containers. Do not store for long periods in direct sunlight.

1.6 JOB CONDITIONS

- A. Environmental Conditions:
 - 1. Do not proceed with application of coating materials when surface temperature is less than 40°F (4.4°C) or if precipitation is imminent.
 - 2. Do not apply material unless surface to receive coating is clean and dry.

1.7 WARRANTY

- A. Upon request, NEOGARD® shall offer the manufacturer's standard warranty upon receipt of a properly executed warranty request form.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. NEOGARD® Division of JONES-BLAIR™ Company, P.O. Box 35286, Dallas, TX 75235, Toll Free (800) 321-6588, Fax (214) 357-7532, www.neogard.com.

2.2 MATERIALS

- A. Fluid-Applied Roofing Materials:
1. Elastomeric Base Coat: 7419 polyurethane coating, black in color.
 2. Elastomeric Top Coat: 7440 series polyurethane coating material. Standard colors are gray, tan and white.
 3. Flashing Tape: 86218 flashing tape (WebSeal™) or approved equal having a minimum thickness of 30 mils.
 4. Sealant: 70991 or other polyurethane sealant approved by NEOGARD®.
- B. Physical properties of cured fluid-applied roofing materials used on this project are:

PERFORMANCE REQUIREMENTS OF CURED FILM			
PHYSICAL PROPERTIES	TEST METHOD	BASE COAT	TOPCOAT
Tensile Strength	ASTM D412	350 psi	2,500 psi
Elongation	ASTM D412	500%	450%
Permanent Set	ASTM D412	<25%	15%
Tear Resistance	ASTM D1004	100 lb/in	250 lb/in
Water Resistance	ASTM D471	<3% @ 7 days	2.5% @ 7 days
MVT @ 30 mils	ASTM E96	1.6 English	1.3 English
Taber Abrasion	ASTM D4060	N/A	15 mg/1,000cs-17
Shore A	ASTM D2240	50 - 55	77 - 85
Adhesion	ASTM D903	5 pli	30 pli
Weathering Resistance	ASTM D822	N/A	Slight Chalk
Thermal Shock	Alternate Heat/Cold	No Loss of Adhesion	No Loss of Adhesion

2.3 ACCESSORIES

- A. Fabric reinforcement and waterproofing coverings for expansion joints shall be compatible with specified fluid-applied roofing system.
- B. Miscellaneous materials such as adhesives, metal primers, metal vents and drains shall be a composite part of the roof system and shall be compatible with the fluid-applied roofing system.
- C. Roofing Granules: Granules shall be number 11 screen size, dust free, ceramic-coated roofing granule. Use only granules as approved by NEOGARD®. Color shall be off-white, or as otherwise selected by Owner.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Inspect roof surfaces to insure they are clean, smooth, sound, properly prepared and free of moisture, dirt and debris.
- B. Verify structural decking is securely supported and attached.
- C. Verify all roof penetrations, mechanical equipment, cants, gravel stops and all other on-roof items are in place and secure.
- D. Verify all roof drains are clean and in working order.
- E. Verify that all air conditioning and air intake vents are suitably protected or closed.
- F. Verify all critical areas in the vicinity of the application area are suitably protected.

3.2 PREPARATION

- A. Protection:
1. Keep products away from heat, sparks and flames. Do not allow the use of spark producing equipment during application and until vapors are gone. Post "No Smoking" signs.
 2. The overspray and/or solvents from spraying fluid-applied roofing materials can carry considerable distances and care should be taken to do the following:
 - a. Post warning signs a minimum of 100 feet from the work area.
 - b. Close air intakes into building and/or air conditioner intakes.
 - c. Set up windbreaks when needed.
 - d. Minimize or exclude all personnel not directly involved with the coating application.
 - e. Have CO₂ or other dry chemical fire extinguishers available at the jobsite.
 - f. Provide adequate ventilation.
 3. Protect plants, vegetation and animals which might be affected by the coatings. Use drop cloths or masking as required.
- B. Surface Preparation:
1. Thoroughly brush and vacuum existing roof, removing all loose dirt and other foreign contaminants. **Note: Built-up roofs with embedded gravel must be spudded to obtain a surface as smooth as possible.**
 2. Remove all existing abandoned mechanical equipment, deteriorated roofing materials, adhesives and foreign materials down to sound substrate. Replace these areas with similar

- materials to match existing roof level. The width, adhesion and/or fastening requirements of the new material must be compatible with the existing roof and meet local codes. Seal all edges as described in Section 3.2 B4 of this guide specification.
3. Wet areas shall be removed. Replace with similar roofing materials to match existing roof level. The width, adhesion and/or fastening requirements of the new material must be compatible with the existing roof and meet local codes. Seal all edges as described in Section 3.2 B4 of this guide specification.
 4. Repair all blisters, splits, fishmouths, seams, holes and other surface imperfections of the roof and flashing areas with similar roofing materials. The width, adhesion and/or fastening requirements of the new material must be compatible with the existing roof and meet local codes. Over the repair, apply elastomeric base coat at a rate of 1 gallon per 100 square feet (100 sf/gal) minimum. Elastomeric base coat shall extend a minimum of 4 inches beyond the edges of the repair.
 5. Thoroughly clean all exposed metal surfaces such as pipe sleeves, drains, boxes, ducts, etc. remove all loose paint, rust and asphalt or loose roofing materials of any kind.
 6. Seal watertight gutters, parapet walls and caps. Repair any damaged metal. Caulk and seal watertight all screws, seams, skylights, joints, pipes, voids, protrusions and any areas where water could enter through the roof.
 7. Clean and seal all drains watertight.
 8. Allow roof and other prepared surfaces to dry completely before proceeding with coating application.

3.3 APPLICATION

- A. Elastomeric Coating Application:
 1. Apply elastomeric base coat at a minimum rate of 1 gallon per 100 square feet (100 sf/gal) to roof surfaces that will receive the fluid-applied roofing system to yield an average thickness of 13 dry mils.
 2. When dry, apply second elastomeric base coat at a minimum rate of 1 gallon per 100 square feet (100 sf/gal) to yield an average thickness of 13 dry mils.
 3. When dry, apply third elastomeric base coat at

a minimum rate of 1 gallon per 100 square feet (100 sf/gal) to yield an average thickness of 13 dry mils.

4. When dry, apply elastomeric topcoat at a minimum rate of 1 gallon per 100 square feet (100 sf/gal) to yield an average thickness of 12 dry mils.
5. When dry, apply elastomeric topcoat at a minimum rate of 3/4 gallon per 100 square feet (133 sf/gal) to yield an average film thickness of 9 dry mils and immediately broadcast number 11 roofing granules into wet coating at a rate of 35 pounds per 100 square feet. Allow to cure a minimum of overnight or until it can be walked on. When dry, remove excess aggregate. Total system coating thickness averages 60 dry mils.

*Note to specification writer: Thickness values of cured film are averages and can vary due to finish of surface. High sloped roofs may require additional coats to achieve specified dry film thickness.

3.4 CLEANING

- A. Remove debris, resulting from completion of fluid-applied roofing operation, from the project site.

3.5 PROTECTION

- A. After completion of application, do not allow traffic on coated surfaces for a period of at least 48 hours at 75°F and 50% R.H., or until completely cured.

END OF SECTION

The information, data and suggestions contained herein are believed to be reliable, based upon our knowledge and experience; however, it is expressly declared that Seller does not guarantee the result to be obtained in Buyer's process. **SELLER HEREBY EXPRESSLY DISCLAIMS ANY IMPLIED WARRANTY OF MERCHANTABILITY FOR FITNESS FOR A PARTICULAR PURPOSE AND/OR ANY OTHER WARRANTY, EXPRESS OR IMPLIED** as to any and all products and/or suggestions described herein, whether such products are used alone or in combination with other materials. Buyer must make its own determination of the suitability of any product for its use, and the completeness of any information contained herein. Nothing contained herein shall be construed to constitute inducement or recommendation to practice any invention covered by any patent without authority from the owner of the patent. Applicator is an independent contractor of, and should under no circumstances be viewed as an employee or agent of, the NEOGARD® Division of JONES-BLAIR®. DBElastaGardBURMB.indd

NEOGARD®
Div. of JONES-BLAIR®

2728 Empire Central - P.O. Box 35286 - Dallas, Texas 75235 - Toll Free (800) 321-6588 - Fax (214) 357-7532 - www.neogard.com